

1. **On how many properties EPS has been installed** - *491 properties*
2. **of the properties which had it installed, how many had (i) fire retardant and (ii) non-fire retardant EPS installed** - *All properties have non-fire retardant 90mm EPS Boards installed and the system is classified as European Classification Bs-1, in accordance with BS EN 13501-01*
3. **How many of those properties EPS been removed from** - *No properties have the system removed*
4. **of the properties which had EPS installed, how many had 6mm or more of render cover installed** - *All properties have 6mm or more render cover*